

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 61643-32
Edition 1.0 2017-09

IEC 61643-32
Édition 1.0 2017-09

Low-voltage surge protective devices –

**Part 32: Surge protective devices connected to
the d.c. side of photovoltaic installations –
Selection and application principles**

Parafoudres basse tension –

**Partie 32: Parafoudres connectés au côté
courant continu des installations
photovoltaïques – Principes de choix et
d'application**

CORRIGENDUM 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

Annex D (informative) – Exceptions in the USA related to Class I tested SPDs

Replace the existing text of Annex D with the following new text:

In the USA, Class I tested SPDs are not required. This exception applies to the entire document and in particular to the following locations:

Clause	Subclause	Paragraph/Table/Figure	Line of paragraph
3	3.23	Note 2	1 st Line
6	6.1	Table 1	Entire Table
6	6.2.1	Figure 1, Legend	3 rd line
6	6.2.2	Figure 2, Legend	3 rd line
6	6.2.3	Figure 3, Legend	1 st line, 2 nd line, 3 rd line, 4 th line
6	6.2.3	1st Paragraph below Figure 3	2 nd line
6	6.2.3	3rd Paragraph below Figure 3	1 st line
7		10 th paragraph	5 th line
9	9.1.2	2 nd paragraph	1 st line
9	9.2.2	2 nd paragraph	1 st line
9	9.2.6	2 nd paragraph	1 st line
9	9.2.6	3 rd paragraph	1 st line
9	9.2.6	9 th paragraph	5 th line
Annex A	A.1	2 nd paragraph	1 st line