



Technical drawings — Installations — Graphical symbols for automatic control

Dessins techniques — Installations — Symboles graphiques pour systèmes de commande automatiques

Draft International Standard ISO/DIS 4067/3 was submitted in 1979 to the combined voting procedure, but it did not meet the minimum voting requirements necessary for its publication as an International Standard.

In 1982 the members of ISO/TC 10 agreed by majority vote to publish ISO/DIS 4067/3 as Technical Report (type 1) ISO/TR 8545, until such time as coordination problems within ISO/TC 10 have been solved.

1 Scope and field of application

This Technical Report establishes a series of graphical symbols for equipment and functional connections, for use on drawings and diagrams for the installation of automatic control systems.

The majority of the symbols are shown in conjunction with their corresponding functional connection lines.

The size of the symbols shall be related to the scale of the drawing.

If a more detailed representation is required, the symbols can be combined with designations indicated on the drawing or in a separate schedule.

For representation on flow sheets for more advanced process systems, ISO 3511/1 is recommended.

2 References

ISO 128, *Technical drawings — General principles of presentation*.

ISO 1219, *Fluid power systems and components — Graphic symbols*.

ISO 3511, *Process measurement control functions and instrumentation — Symbolic representation —*

Part 1 : Basic requirements.

Part 2 : Extension of basic requirements.¹⁾

Part 3 : Detailed symbols for instrument interconnection diagrams.¹⁾

¹⁾ At present at the stage of draft.

3 Symbols for control and regulating systems

No.	Description	Basic symbol	Application of symbol
3.1	Measuring point	○	
3.2	Two measuring points		
3.3	Transmitter	▽	
3.4	Transmitter with external measuring point		
3.5	Transmitter with internal measuring point		
3.6	Transmitter for measuring differences		
3.7	General control unit	 or 	
3.8	Manual setting device	T	
3.9	Actuator		
3.10	Actuator maintaining position on failure of its energy supply		
3.11	Actuator closing on failure of its energy supply		
3.12	Actuator opening on failure of its energy supply		
3.13	Actuator, automatic		
3.14	Actuator, automatic with manual setting device		